




USER: SIECAW
Frickey, March 17, 2008
DATE: 03-2005
DGN: ... (standard 2008) lwp83.dgn


	CITY PROJECT NO.	SHEET NO.
	LSP	1
	Date: 03-2005	Drawn: CAW
	Scale: NONE	Checked: Approved:




ELECTRIC CONTROL ASSEMBLY




METER PEDESTAL DETAIL




METER POST



SIDE OF BUILDING DETAILS



CONTROL RELAY AND WOOD POWER POLE DETAILS



ELECTRICAL SERVICE NOTE:

EACH RIGID STEEL RISER, EITHER WOOD POLE, OR SIDE OF BUILDING, SHALL BE GROUNDED IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE, LOCAL ORDANCES, APPLICABLE CODES AND THE REQUIREMENTS OF THE LINCOLN ELECTRIC SYSTEM.

THE SIDE OF BUILDING INSTALLATION SHALL REQUIRE A RISER GROUNDING CLAMP, NICO TAP AND NO 6 BARE COPPER. THE NO 6 BARE COPPER WIRE SHALL BE CLAMPED TO THE SERVICE CABLE MESSENGER.

THE SIDE OF POLE INSTALLATION SHALL REQUIRE A RISER GROUNDING CLAMP, NO 6 BARE COPPER, 1/2" x 10' GROUND ROD AND WOOD MOLDING.

PROVIDE SUFFICIENT LEAD LENGTH FOR L.E.S. TO MAKE FINAL ELECTRICAL CONNECTIONS TO SECONDARY.

PHOTO ELECTRICAL CONTROL ASSEMBLY TO BE LOCATED ON NORTH, EAST OR WEST FACE OF POLE WITH PHOTO ELECTRIC CELL WINDOW FACING NORTH.

